



Addendum #1
ITB # 56-23, Portable and Mobile Generators
August 4, 2023

NOTICE IS HEREBY GIVEN that the following addendum serves to provide clarification and to answer the questions received on ITB # 56-23, Portable and Mobile Generators.

Question 1: In reference to Technical specifications / Project#4337-398-R (85kw mobile generators) B1. Control Panel accessories. Four (4) Position Voltage selector 208/240/480 V @ 3ph, and 120/240V single phase - requirement.

Would a standard, Three (3) Position Voltage selector switch, output: 208/480 V @ 3ph and 120/240V single phase, and equipped with a Potentiometer (rheostat), which will allow voltage adjustment when set at 208V, to be increased to 240V, be accepted?

Answer to Question 1: The City of Clearwater will not accept any alternative for the 85kW. Reference DETAILED SPECIFICATIONS, 4. TECHNICAL SPECIFICATIONS. B1 (a), page 16 of the solicitation.

End of Questions and Answers

All other dates and terms and conditions remain the same in this Invitation to Bid.

End of Addenda